

Government of Bihar
public Health engineering Department

District level testing Laboratory:-Siwan

Sample Receiving Date:- 18.01.2023

Sample Collected by:- JEE SIWAN

Sl. No.	Date of Testing	Block	Panchayat	Name of Scheme	Parameters																	
					PH	Turb.	Ec	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	Mn	As	Total Coli		
1	21.01.2023	Siwan sardar	Nagar Fanchayat	Sangmitra public school siwan	7.11	1.2	-	308	235	64	-	72	260	0.23	0.88	45	0.24	0.24	0	<1.1		
Desirable Limits																						
Permission Limits																						

All Parameters are under distable limits

Attested
Mani bdd. DM
Manager
Sangmitra Public School

Sandeep Kumar
Lab Assistant/Chemist D.L.I
P.H. Division, Siwan

Principal
PRINCIPAL
SANGMITRA PUBLIC SCHOOL
SIWAN (BIHAR)
AFFILIATION NO. 330337